

**NORTH DAKOTA STATE WATER COMMISSION  
PROJECT 1736**

**ADDENDUM NO. 2**

**TO THE CONTRACT DOCUMENTS  
FOR  
DODGE AND RICHARDTON PUMP STATION UPGRADES  
SWPP CONTRACT 4-1E/4-2B**

**JULY 2018**

**NOTICE IS HEREBY GIVEN TO BIDDERS** that in reference to the CONTRACT DOCUMENTS of the above referenced contract, the following will be noted:

1. SPECIFICATION SECTION 432150 – VERTICAL TURBINE PUMPS

Modify Part 3.D.8 as follows:

"8. Performance tests shall be "full-scale." The complete pump ~~and pump can~~, including column and discharge elbow, shall be used. Measuring devices shall have been calibrated within the previous year."

**This document was originally issued and sealed by Jim Lennington, Registration Number 3251 on 08/06/2018. The original document is stored at Bartlett & West. This document is only valid in the certified electronic format with digital signatures present on this page.**